

Assessment Details

Team/School: RUISLIP LIDO
Reference: 783
Is This Confidential: No
Publish To Portal: No
Description: Ruislip Lido Splash pad legionella bacteria
Exact Location / Non-council Parks & Open Spaces - Ruislip Lido
Site (enter address details): 214861
Council Site: 
Assessor Employee Number: 
Assessor Forename(s): 12/07/2021
Assessor Surname: 12/07/2021
Assessment Date: 12/07/2021
Date Record Created: 12/07/2021
Date Modified: 1000
Assessment Team Members: 1000
Assessment Date: Children and adults
Number Of People Exposed:
People Exposed:

Project Risk Assessment Reference

Reference	Description	Assessor Name	Org Unit	
-----------	-------------	---------------	----------	--

Hazards And Control Measures

Hazard Category	Hazard Phrases	Persons At Risk	How Is Person At Risk	Control Measures	Potential Risk Factor	Additional Control Measures	Residual Risk Factor
Childrens Centres - Outdoor Play Area.	Splash pad/ water play	Children and adults	catching Legionella from contaminated water	Splash pad system is cleaned and prepared for use. Water system sterilized before start up. A self start cycle each morning before first use. Heads of play jets are jet washed 4 times throughout Summer.	4 Low Risk	Water quality checked monthly during the Summer months.	4 Low Risk

Greatest Potential Risk Level: 4

Greatest Residual Risk Level: 4

Conclusion

If All Additional Controls Are Implemented Are The Risks At An Acceptable Level?:
Assessment Conclusion: Yes

Record Detail

Language: English (UK)
Date Record Created: 12/07/2021
Created By: [REDACTED]

Record Approval

Stage	Date	By	Assigned	Submission Due Date	Approver	Approved?	Comments
Auto Assigned	12/07/2021	[REDACTED]	[REDACTED]	19/07/2021		No	
Submitted	27/07/2021	[REDACTED]			[REDACTED]	No	
Approved (Current)	27/07/2021	[REDACTED]			[REDACTED]	Yes	